

Certificate of Compliance

Certificate: 1844341

Master Contract: 237144

Project: 1844341

Date Issued: October 26, 2006

Issued to: HARTING Electric GmbH & Co., KG
Wilhelm-Harting-Strasse 1
Espelkamp, 32339
GERMANY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by:

Carole Lemay

Authorized by:

Helene Vaillancourt
Operations Manager

PRODUCTS

CLASS 5311 87 - POWER SUPPLIES - Component Type - (CSA 60950-1-03/UL 60950-1, First Edition, NRTL Program) - Certified to U.S. Standards
CLASS 5311 07 - POWER SUPPLIES - Component Type (CSA 60950-1-03)

- Din rail component type switching mode power supplies*, Class II, models and rating as follow :
pCon 2060-24; Rated : Input: 100-240Vac, 50/60Hz, 1.3A and 120-350Vdc / Output: 24Vdc @ 2,5A adjustable from 23,0 to 29,0Vdc.
pCon 2060-48; Rated : Input: 100-240Vac, 50/60Hz, 1.3A and 120-350Vdc / Output: 48Vdc @ 1,25A adjustable from 47,0 to 52,0Vdc.

*Note: Units were evaluated as components where the suitability of the combination must be determined with the end use product.

MARKINGS

Listee's name and/or CSA file number 237144, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.

The cCSAus monogram may appear next to the CSA Mark